



Republic of the Philippines
Department of Health
BAGUIO GENERAL HOSPITAL AND MEDICAL CENTER
Baguio City

**BIDS AND AWARDS COMMITTEE
SUPPLEMENTAL/BID BULLETIN**

Form No.: MCC-BAC-013

Revision No.: 1

Effectivity Date: September 1, 2016

Bid Bulletin No.: 2021-009
Date: October 19, 2021

This Bid Bulletin No. 2021-009 is issued to modify or amend the Invitation to Bid of the projects:

1.) Procurement of Various IT Equipment

This shall form integral part of said Invitation to Bid.

TECHNICAL SPECIFICATIONS

ORIGINAL SPECS	AMENDED
Forty-Five (45) set DESKTOP COMPUTER WITH UPS 700 Watts Bronze Rated Power Supply or higher Uninterruptible Power Supply: 3 or more universal socket	Forty-Five (45) set DESKTOP COMPUTER WITH UPS 700 Watts Bronze Rated Power Supply or higher or manufacturers specification Uninterruptible Power Supply: 3 or more universal socket / NEMA SOCKET
Nine (9) units LAPTOP External display (VGA) port	Nine (9) units LAPTOP External display (VGA) port / adapter for VGA
Two (2) units HIGH FREQUENCY RACK MOUNTING ONLINE UPS Supplier must be authorized distributor of the offered item	Two (2) units HIGH FREQUENCY RACK MOUNTING ONLINE UPS Supplier must be authorized distributor / reseller of the offered item

CLARIFICATIONS

QUESTIONS	ANSWER
Two (2) units HIGH FREQUENCY RACK MOUNTING ONLINE UPS 1. 5 mins Back-up Time (Full Load) - What is the load equipment rating? 2. Whether the three (3) years warranty on parts and service includes the battery?	1. Can back-up a load of 10kVA for five (5) minutes 2. Yes, the battery is included in the three (3) years warranty under "Parts".

BIDS AND AWARDS COMMITTEE I

SGD

LARRY C. HAYA JR, MD

Chairperson

SGD

VALORIE B. PRESCO, RN

Member

SGD

JOSELITO M. DATUD, RN

Member

SGD

ANDREW S. SIB-ATEN

Member

SGD

JERILYN L. DULAY, MD

Vice Chairperson

SGD

DENNIS M. DOMINGUEZ, MD

Member

SGD

RANDY B. SAMONTE

Member

Approved by:

SGD

RICARDO B. RUNEZ, JR., MD, FPCS, MHA, CESE

Medical Center Chief II